



OIL AND NATURAL GAS CORPORATION LTD

MUMBAI REGION, FIRE SECTION, PANVEL
FIRE STATION , PHASE-II, ONGC , PANVEL
NAVI MUMBAI-410221, TEL: 27453673


No: WOU/PNL/Fire/KVS/09-2022

DATE: 12.09.2022

Sub: Fire Equipments Maintenance Certificate

This is to certify that the following list of Fire Equipments are available at Kendriya Vidyalaya ,ONGC ,Panvel and are being maintained by Fire Section ,ONGC Panvel and are in working condition.

Sr. No	Type of Equipment	Quantity (In Nos)	Place of Equipment	Date of Last Maintenance Done	Status of Equipment
Fire Extinguishers					
01	DCP Fire Extinguisher(6Kg) Capacity	18	All entrance ,Ground Floor & 1 st floor,Labs,Office etc	09-08-2022	Working Condition
02	Co2 Fire Extinguisher(4.5Kg) capacity	22		09-08-2022	Working Condition
Fire Detection and PA system					
01	Smoke Detectors	150	Ground Floor & 1 st Floor	04-08-2022	Working Condition
02	P A System	01	At Reception	04-08-2022	Working Condition
Fire Hydrant System					
01	Hydrant	16	Out side Building of KV School	20-07-2022	Working Condition
02	Hydrant	08	In side Building of KV School Ground Floor & 1 st Floor	26-07-2022	Working Condition
03	Hose Reel	08	In side Building of KV School Ground Floor & 1 st Floor	26-07-2022	Working Condition
Other Miscellaneous Equipments					
01	Water Monitor Trolley Mounted	02	Maintained at Fire station	Physically Checked	Working Condition
02	Extension Ladder	02	Maintained at Fire station	Physically Checked	Working Condition
03	Fire Blanket	05	Maintained at Fire station	Physically Checked	Working Condition


12/09/2022

C.M. KHARE

सी. एम. खरे

Sr. Fire Officer

वरिष्ठ अग्निशमन अधिकारी
ONGC LTD. PANVEL